

# County of San Diego Planning & Development Services BUILDING DIVISION

## ACCESSIBILITY CORRECTION LIST

Multifamily Housing

2A

**Parking Facilities** 

RECORD ID:	OWNER ON APPLICATION:

#### **SCOPING**

- 1. The accessibility provisions of this correction list apply to the following parking facilities serving covered multifamily dwellings and associated common-use facilities:
  - Garages
  - Private garages

Exception: An attached private garage directly serving a single covered multifamily dwelling unit with one of the following:

- o Interior door leading directly from dwelling unit to garage and complying with provisions of accessibility correction list 15A
- Accessible route from dwelling unit to exterior door entering garage with both dwelling unit and garage doors complying with provisions of accessibility correction list 15A
- Accessible route from dwelling unit's primary entry door to vehicular entrance to garage with dwelling unit door complying with provisions of accessibility correction list 15A
- Carports
- ☐ Off-street parking (e.g., parking lots or spaces)

CBC 1109A.1 and CBC 1109A.2

2. Identify on site accessibility plan accessible parking spaces numbering minimum 2% of covered multifamily dwelling units with at least one accessible space provided in each type of parking facility.

CBC 1109A.3

- 3. Where assigned parking provided for residents or groups of residents, identify on site accessibility plan minimum 2% of assigned spaces serving covered multifamily dwellings as accessible with at least one accessible space provided in each parking facility type
  CBC 1109A.4
- 4. Where assigned parking provided, designated accessible parking serving a covered multifamily dwelling unit shall be provided upon request of residents and with full range of choices e.g., off-street parking, carport, garage available for other residents.

CBC 1109A.6

5. Where unassigned and visitor parking provided, identify on site accessibility plan minimum 5% of parking spaces as accessible and providing access to grade-level entrances of covered multifamily dwellings and associated facilities.

CBC 1109A.5

6. Identify on site accessibility plan one of every eight accessible parking spaces – but not less than one – as van accessible.

CBC 1109A.8.6

7. Identify on site accessibility plan accessible routes between parking spaces and building entrances using **\*\*\*\*\*** or equivalent symbol.

CBC 1109A.7

8. Accessible parking spaces shall be located on shortest accessible route to accessible building or covered multifamily dwelling unit

Exception: All van accessible spaces may be grouped on one level of a multilevel parking facility

CBC 1109A.7(1)

In parking facilities not serving a particular building, accessible parking spaces shall be located on shortest accessible route to an accessible pedestrian entrance to parking facility.

CBC 1109A.7(4)

10. In buildings with multiple entrances with adjacent parking, accessible parking spaces shall be dispersed to serve each entrance. CBC 1109A.7(2)

THIS DOCUMENT IS FOR PLAN REVIEW ONLY.

CORRECTION LIST ITEMS AND FIGURES MAY NOT BE REPRODUCED OR COPIED ON PLANS.

IF CONFLICTS EXIST BETWEEN CODE TEXT AND FIGURES, THE CODE TEXT SHALL GOVERN.

5510 OVERLAND AVE, SUITE 110, SAN DIEGO, CA 92123 • (858) 565-5920 • (888) 336-7553 HTTP://WWW.SDCPDS.ORG

PDS 626A REV: 03/01/2014 PAGE **1** of 4

11. Accessible parking space locations shall not compel persons with disabilities to wheel or walk behind parked cars other than their own.

CBC 1109A.7(5)

12. Accessible routes shall not cross lanes for vehicular traffic when practical.

Exception: When crossing vehicular traffic lanes is necessary, accessible route shall be designated and marked as crosswalk

CBC 1109A.7(3)

### **DIMENSIONS AND CONFIGURATION**

13. Provide complete dimensions and coordinated detailing for each accessible parking space.

CBC 1109A.8

- 14. Where individual accessible parking spaces are provided, dimension the following per CBC Figure 11A-2B:
  - ☐ Minimum 9-foot-wide by 18-foot-long parking stall
  - ☐ Minimum 5-foot-wide by 18-foot-long access aisle on passenger side of vehicle

Exception: Minimum 8-foot-wide by 18-foot-long access aisle required on passenger side of van accessible spaces





FIGURE 11A-2B SINGLE AND VAN ACCESSIBLE PARKING STALLS

CBC 1109A.8.5 and CBC 1109A.8.6

- **15.** Where dual accessible parking spaces are provided, dimension the following per CBC Figure 11A-2A or CBC Figure 11A-2C:
  - ☐ Two minimum 9-foot-wide by 18-foot-long parking stalls
  - ☐ Minimum 5-foot-wide by 18-foot-long access aisle between parking stalls

Exception: Minimum 8-foot-wide by 18-foot-long access aisle required on passenger side of van accessible spaces



#### FIGURE 11A-2A DOUBLE PARKING STALLS




FIGURE 11A-2C DIAGONAL PARKING STALLS

16.	dentify on site accessibility plan minimum 98-inch vertical clearance at the following locations within each parking faci   Exception: Lower vertical clearance acceptable for vehicular passageways serving inaccessible parking spaces if reflowarning signs provided where entering areas with less than 98-inch vertical clearance  Entrances  Exits  Accessible parking spaces and access aisles	
	☐ Vehicular passageways serving accessible spaces  Cl	BC 1109A.8.1
17.	Specify maximum 2.1% slope in all directions at surfaces of accessible parking stalls and access aisles.  Cl	BC 1109A.8.3
18	8. Provide bumpers or curbs at all applicable parking stalls – accessible and otherwise – to prevent vehicle encroachment in	
	equired width of adjacent pedestrian ways.	: 1109A.8.2(1)
10	Where curbs separate access aisles and adjacent pedestrian ways, provide curb ramps per accessibility correction li	
13.	encroachment into accessible parking stalls or access aisles.	
		: 1109A.8.2(2)
	ITIFICATION AND SIGNAGE	
20.	The identification and signage requirements of items 21 through 26 do not apply to accessible assigned parking spa per item 3.	aces provided
		CBC 1109A.4
21.	Detail surface identification complying with one of the following configurations at each accessible parking stall:  Outlined 36-inch by 36-inch International Symbol of Accessibility in white on blue background and located for visil	bility by traffic
	enforcement personnel when vehicle properly parked  Stall outlined or painted blue with International Symbol of Accessibility outlined in white or color	r contrasting
	pavement/background CI	BC 1109A.8.8
22.	Detail surface identification complying with the following at each accessible parking access aisle:	
	☐ Blue access aisle border☐ Blue or white hatched lines maximum 36 inches on center within access aisle☐	
	"NO PARKING" painted on ground within access aisle in white letters minimum 12-inches high and located for traffic enforcement personnel	or visibility by
	·	1109A.8.5(4)
23.	dentify on site accessibility plan location of each parking-related sign required per items 24 through 26 and coordinate signage schedule and/or details indicating the following:  ☐ Sign dimensions	e with
	☐ Character and symbol dimensions, colors, and background colors ☐ Sign placement (e.g., post-mounted, wall-mounted)	
	☐ Horizontal/vertical clearance dimensions from pedestrian ways Cl	BC 1109A.8.8
24.	Provide sign complying with the following adjacent to and visible from each accessible parking space:  International Symbol of Accessibility symbol in white on blue background  Minimum 70 square inches  Minimum 80-inch vertical clearance above any adjacent pedestrian ways  Execution Sign also may be contered on a well at an interior and of parking appeared this inch height	
	Exception: Sign also may be centered on a wall at an interior end of parking space at minimum 36-inch height  Reflectorized surface	
		BC 1109A.8.8
25.	Provide signage reading "Van Accessible" at each van-accessible parking space with minimum 80-inch vertical clea any adjacent pedestrian ways	arance above
	CI	BC 1109A.8.8
26.	Provide tow-away warning signs complying with the following:  Posted conspicuously at each parking facility entrance or adjacent to and visible from each accessible parking spanning in Minimum 17 inches by 22 inches  Minimum 1-inch-high lettering  Reading: "Unauthorized vehicles parked in designated accessible spaces not displaying distinguishing placards of license plates issued for persons with disabilities will be towed away at the owner's expense. Towed vehicles materials and the control of the total physics."	or special
	reclaimed at or by telephoning"  Tow-away contact information specified on sign detail	

PDS 626A REV: 03/01/2014 PAGE 4 of 4